



Top latching hardware, when used on 20-90 minute labeled or stamped doors (UL or WH), is only allowed on pairs. This hardware cannot be used on single swing applications or where the pairs include a mullion between the doors. This includes any hardware that has only one self latching mechanism located at the top of the door. It does not include full rod hardware, rim exits or mortised exit hardware.

Top latching hardware, also referred to as less bottom rod, has only been evaluated for applications where the bottom of both leaves of a pair can move together. A fire test would be required to insure the door movement, during a fire, relative to a fixed frame or mullion would meet the deflection criteria of the fire test method.



**Stile & Rail Doors, Door Frames,
Plywood, Veneered Components**

Two Rivers Division
One Eggers Drive
Two Rivers, WI 54241
Phone: 920.793.1351
Fax: 920.793.2958

www.eggersindustries.com

Flush Doors

Neenah Division
164 North Lake Street
Neenah, WI 54956
Phone: 920.722.6444
Fax: 920.722.0357

email: sales@eggersindustries.com