

Electric Strikes

Information Bulletin 458



Eggers Industries

Date: March, 2013

Eggers has approval with UL to put electric strikes in 20-minute doors. Mineral core doors are only available with a construction tag and will require the use of a non-combustible lock block with the electric strike. The Electric strikes must be listed and approved by UL on both the 20-min and construction tag doors.

Eggers has approval to apply ITS (Warnock Hersey) labels on 45-90 min rated doors having electric strikes, when constructed per the Georgia Pacific (GP) approvals. The Electric strikes are restricted to mortise dimensions of 1-7/16" wide by 3-7/8" high by 2-3/8" deep and must be positive pressure listed and labeled for 45 to 90 minute solid core fire doors.

Because this is a GP listing none of our "Eggers specific" constructions and approvals such as veneer-wrapped lite beads, 45-min full lites, CVR hardware w/o metal edges, and others cannot be used with this application. Until configuration can be added to define the available combinations please contact the technical department to discuss requested option combinations.



Stile and Rail Doors,
Door Frames, Plywood
Veneered Components

Two Rivers Division
One Eggers Drive
Two Rivers, WI 54241
Phone: 920.793.1351
Fax: 920.793.2958

Flush Doors

Neenah Division
164 North Lake Street
Neenah, WI 54956
Phone: 920.722.6444
Fax: 920.722.0357

Architectural Veneer Faces,
Custom Wood Products,
Plywood

Kentucky Division
2125 Lake Jericho Road
Smithfield, KY 40068
Phone: 502.845.0154
Fax: 502.849.0444