

Pairs with Different Core Types

Information Bulletin #328



Eggers Industries

Date: August, 2017

In accordance with the limitations shown below, Eggers will construct pairs of doors having different core types. In addition, a flush leaf may be paired with a stile & rail leaf.

Specific application rules:

- Because different core react differently to fire, both leaves of a fire-rated pair must be constructed of the same core type.
- Where bullet-resistance is required, both leaves are required to have the same construction.
- Where lead-lining is involved (other than designed acoustical core construction SG-5, SG-6, SG-14 and SG-16) both leaves must include lead. The lead thickness and the core type may differ between the two leaves.
- Where one leaf is includes a designed acoustical core construction (SG-3, SG-4, SG-5, SG-6, SG-12, SG-14 and SG-16) the other must be a designed acoustical core construction, though not necessarily the same construction [example one leaf could be SG-4 and the other SG-5]. No STC guaranty is available for such combinations.

Special Notes:

1. Availability of face-matching may be limited, based on the constructions selected,
2. Hardware options and maximum opening height may be limited by the combination selected,
3. Some combination may impact lead-time



Stile & Rail Doors, Door Frames, Plywood, Veneered Components

Two Rivers Division
One Eggers Drive
Two Rivers, WI 54241
Phone: 920.793.1351
Fax: 920.793.2958

www.eggiersindustries.com

Flush Doors

Neenah Division
164 North Lake Street
Neenah, WI 54956
Phone: 920.722.6444
Fax: 920.722.0357

email: sales@eggiersindustries.com